

ANNEXURE 7

Infrastructure Assessment – Power and Phone

14 December 2010.

DKW.12/4B.

Survus Consultants,
Surveyors & Engineers,
P O Box 5558,
CHRISTCHURCH.

Attention: Mr Andrew Cain.

Dear Sirs,

POSSIBLE SUBDIVISION: 1486 SPRINGS ROAD, LINCOLN.

In reply to your email of 7 December 2010, we advise that the development will be able to be supplied from Orion's electrical network, with Orion carrying out any upstream reinforcement if necessary. About two or three electrical kiosk sites will be required within the subdivision.

The development will be subject to Orion's connection and extensions policy applicable at the time of application for the connection. For specific design and costing requirements, your client will need to employ the services of an Orion accepted electrical design consultant.

Corridors for clearances from high voltage lines will be required along the Springs Road frontage and along the northern boundary of the development.

Yours sincerely,



David Wade.

LAND CO ORDINATOR.

DD Phone: 363 9850. Fax 363 9707.

Email: david.wade@oriongroup.co.nz.



Since 1994, proud supporter of community energy action
charitable trust

ORION NEW ZEALAND LIMITED
218 Manchester Street, PO Box 13896, Armagh, Christchurch 8141, New Zealand
PHONE +64 3 363 9898 | FAX +64 3 363 9899 | oriongroup.co.nz

Fiona Aston

From: Andrew Cain [andrew@survus.co.nz]
Sent: Monday, 20 December 2010 9:14 a.m.
To: fiona.aston@xtra.co.nz
Subject: FW: Subdivision 1486 Springs Road, Lincoln

Hi Fiona,

Confirmation from Telecom regarding reticulation at Springs Rd.

Regards

Andrew Cain
Project Manager



surveying engineering property development

4 Meadow Street, PO Box 5558
Papanui, Christchurch
P 03 352 5599
F 03 352 5527

From: Don Baskett [mailto:Don.Baskett@chorus.co.nz]
Sent: Monday, 20 December 2010 9:10 a.m.
To: 'andrew@survus.co.nz'
Cc: 'Nathan Kroening'
Subject: Subdivision 1486 Springs Road, Lincoln

Andrew

SG file reference LCN14267

With regard to your question about extending Chorus network cabling to the subdivision location sent to The Subdivision Group 07.12.10.

We can extend fibre cabling to the subdivision location and would look to offer fibre to the home network reticulation throughout the subdivision area. We will not forward a reticulation agreement offer letter at this stage, as I understand that you are at a feasibility planning stage at present.

Give me a call if you have any further queries.

Nathan

Please file as "NDS email to consultant 20.12.10"

Regards

Don Baskett

Senior Delivery Specialist

+64 3 546 0899 (extn 35899)

+64 3 548 4953

027 473 3261

den.baskett@chorus.co.nz

www.chorus.co.nz



Chorus

A Telecom New Zealand Business

Level 2, Exchange Building, 30 Halifax Street, Nelson
Private Bag 27

This communication, including any attachments, is confidential. If you are not the intended recipient, you should not read it - please contact the sender immediately, destroy it, and do not copy or use any part of this communication or disclose anything about it. Thank you. Please note that this communication does not designate an information system for the purposes of the Electronic Transactions Act 2002."

This has been cleaned & processed by www.defenda.co.nz

NOD32 5716 (20101219) Information

This message was checked by NOD32 antivirus system.
<http://www.eset.com>

Information from ESET NOD32 Antivirus, version of virus signature database 5716 (20101219)

The message was checked by ESET NOD32 Antivirus.

<http://www.eset.com>