

Consent Notes:

- Where a watering point is to be replaced or is required on a subdivision from a water race beyond the boundary the water shall be delivered via a pipe to the trough to eliminate water loss. Adjacent landowners must be consulted as right of access is not guaranteed.
- The level of the top of the trough is to be higher than the level of the water race from which it is piped unless a ball cock is installed to prevent overflow.
- Where the ground is higher than the adjacent race the site must be excavated for the trough.
- The pipe is not a council owned asset and will be owned by the applicant.
- Applicant to mark the inlet site with a marker post, so that it is easily identifiable to all utility providers
- Applicant to ensure the marker post is in place and visible at all times.

