

Sampling Date	Determinand	1/2 MAV	Result	Units
10/08/2017	NO3	25	21.5	mg/L
4/07/2017	NO3	25	22.8	mg/L
6/09/2017	NO3	25	22.5	mg/L
11/10/2017	NO3	25	24.4	mg/L
6/11/2017	NO3	25	24.4	mg/L
8/12/2017	NO3	25	22	mg/L
8/01/2018	NO3	25	23	mg/L
6/02/2018	NO3	25	22	mg/L
11/04/2018	NO3	25	21.2	mg/L
8/05/2018	NO3	25	22.7	mg/L
13/06/2018	NO3	25	31.8	mg/L
11/07/2018	NO3	25	24.3	mg/L
7/08/2018	NO3	25	32.5	mg/L
12/09/2018	NO3	25	23.4	mg/L
10/10/2018	NO3	25	23.6	mg/L
5/12/2018	NO3	25	22.6	mg/L
8/01/2019	NO3	25	22.1	mg/L
6/11/2018	NO3	25	23.9	mg/L
20/02/2019	NO3	25	21.9	mg/L
5/03/2019	NO3	25	23.1	mg/L
9/04/2019	NO3	25	21.4	mg/L
8/05/2019	NO3	25	20.7	mg/L
11/06/2019	NO3	25	21.9	mg/L
18/07/2019	NO3	25	22.7	mg/L
18/07/2019	NO3N	5.65	5.13	mg/L
14/08/2019	NO3	25	22.2	mg/L
14/08/2019	NO3N	5.65	5	mg/L
20/09/2019	NO3	25	22.5	mg/L
20/09/2019	NO3N	5.65	5.07	mg/L
8/10/2019	NO3N	5.65	5.58	mg/L
8/10/2019	NO3	25	24.7	mg/L
15/11/2019	NO3N	5.65	3.72	mg/L
15/11/2019	NO3	25	16.5	mg/L
10/12/2019	NO3N	5.65	5.3	mg/L
10/12/2019	NO3	25	23.5	mg/L
7/01/2020	NO3N	5.65	5.97	mg/L
7/01/2020	NO3	25	26.4	mg/L
11/02/2020	NO3N	5.65	5.71	mg/L
11/02/2020	NO3	25	25.3	mg/L
16/03/2020	NO3N	5.65	5.39	mg/L
16/03/2020	NO3	25	23.9	mg/L
21/04/2020	NO3N	5.65	5.15	mg/L
21/04/2020	NO3	25	22.8	mg/L
18/05/2020	NO3N	5.65	5.32	mg/L
18/05/2020	NO3	25	23.5	mg/L
23/06/2020	NO3N	5.65	5.81	mg/L

23/06/2020	NO3	25	25.7	mg/L
2/07/2020	NO3N	5.65	5.4	mg/L
2/07/2020	NO3	25	24	mg/L
2/07/2020	NO3N	5.65	4.9	mg/L
2/07/2020	NO3	25	22	mg/L
20/07/2020	NO3N	5.65	5.2	mg/L
20/07/2020	NO3	25	23	mg/L
18/08/2020	NO3N	5.65	5.65	mg/L
18/08/2020	NO3	25	25	mg/L
24/09/2020	NO3N	5.65	5.17	mg/L
24/09/2020	NO3	25	22.9	mg/L
21/10/2020	NO3N	5.65	5.29	mg/L
21/10/2020	NO3	25	23.4	mg/L
16/11/2020	NO3N	5.65	5.68	mg/L
16/11/2020	NO3	25	25.1	mg/L
14/12/2020	NO3N	5.65	6.02	mg/L
14/12/2020	NO3	25	26.6	mg/L
21/01/2021	NO3N	5.65	5.71	mg/L
21/01/2021	NO3	25	25.3	mg/L
15/02/2021	NO3N	5.65	5.32	mg/L
15/02/2021	NO3	25	23.6	mg/L
22/03/2021	NO3N	5.65	5.34	mg/L
22/03/2021	NO3	25	23.6	mg/L
23/04/2021	NO3N	5.65	5.14	mg/L
23/04/2021	NO3	25	22.8	mg/L
28/05/2021	NO3N	5.65	5.29	mg/L
28/05/2021	NO3	25	23.4	mg/L
15/06/2021	NO3N	5.65	7.24	mg/L
15/06/2021	NO3	25	32.1	mg/L
30/06/2021	NO3N	5.65	5.07	mg/L
30/06/2021	NO3	25	22.5	mg/L
30/06/2021	NO3N	5.65	4.92	mg/L
30/06/2021	NO3	25	21.8	mg/L
13/07/2021	NO3N	5.65	5.07	mg/L
13/07/2021	NO3	25	22.5	mg/L
10/09/2021	NO3N	5.65	5.12	mg/L
10/09/2021	NO3	25	22.7	mg/L
17/01/2022	NO3N	5.65	5.08	mg/L
17/01/2022	NO3	25	22.5	mg/L
10/09/2021	NO3N	5.65	5.13	mg/L
10/09/2021	NO3	25	22.7	mg/L
7/10/2021	NO3N	5.65	5.13	mg/L
7/10/2021	NO3	25	22.7	mg/L
23/12/2021	NO3N	5.65	5.18	mg/L
23/12/2021	NO3	25	23	mg/L
28/12/2021	NO3N	5.65	5.01	mg/L
28/12/2021	NO3	25	22.2	mg/L

17/01/2022	NO3N	5.65	5.37	mg/L
17/01/2022	NO3	25	23.8	mg/L
15/02/2022	NO3N	5.65	5.18	mg/L
15/02/2022	NO3	25	22.9	mg/L
16/03/2022	NO3N	5.65	5.3	mg/L
16/03/2022	NO3	25	23.5	mg/L
14/04/2022	NO3N	5.65	3.63	mg/L
14/04/2022	NO3	25	16.1	mg/L
12/05/2022	NO3N	5.65	7.49	mg/L
12/05/2022	NO3	25	33.2	mg/L
10/06/2022	NO3N	5.65	5.42	mg/L
10/06/2022	NO3	25	24	mg/L
7/07/2022	NO3N	5.65	5.54	mg/L
7/07/2022	NO3	25	24.5	mg/L
12/08/2022	NO3N	5.65	5.62	mg/L
12/08/2022	NO3	25	24.7	mg/L
12/09/2022	NO3N	5.65	5.19	mg/L
12/09/2022	NO3	25	23	mg/L
14/10/2022	NO3N	5.65	6.5	mg/L
14/10/2022	NO3	25	28.8	mg/L
10/11/2022	NO3N	5.65	5.16	mg/L
10/11/2022	NO3	25	22.9	mg/L
8/12/2022	NO3N	5.65	7.62	mg/L
8/12/2022	NO3	25	33.8	mg/L
20/12/2022	NO3N	5.65	5.31	mg/L
20/12/2022	NO3	25	23.5	mg/L
10/01/2023	NO3N	5.65	5.26	mg/L
10/01/2023	NO3	25	23.3	mg/L
28/02/2023	NO3N	5.65	5.43	mg/L
28/02/2023	NO3	25	24.1	mg/L
11/03/2023	NO3N	5.65	5.32	mg/L
11/03/2023	NO3	25	23.6	mg/L
10/04/2023	NO3N	5.65	5.26	mg/L
10/04/2023	NO3	25	23.3	mg/L
4/05/2023	NO3N	5.65	5.83	mg/L
4/05/2023	NO3	25	25.8	mg/L
8/06/2023	NO3N	5.65	5.67	mg/L
8/06/2023	NO3	25	25.1	mg/L
12/07/2023	NO3N	5.65	5.54	mg/L
12/07/2023	NO3	25	24.6	mg/L
9/08/2023	NO3N	5.65	4.81	mg/L
9/08/2023	NO3	25	21.3	mg/L
13/09/2023	NO3N	5.65	5.13	mg/L
13/09/2023	NO3	25	22.7	mg/L
26/09/2023	NO3N	5.65	5.75	mg/L
26/09/2023	NO3	25	25.5	mg/L