

Sampling Date	Determinand	1/2 MAV	Result	Units
8/10/2017	NO3	25	21.5	mg/L
7/4/2017	NO3	25	22.8	mg/L
9/6/2017	NO3	25	22.5	mg/L
10/11/2017	NO3	25	24.4	mg/L
11/6/2017	NO3	25	24.4	mg/L
12/8/2017	NO3	25	22	mg/L
1/8/2018	NO3	25	23	mg/L
2/6/2018	NO3	25	22	mg/L
4/11/2018	NO3	25	21.2	mg/L
5/8/2018	NO3	25	22.7	mg/L
6/13/2018	NO3	25	31.8	mg/L
7/11/2018	NO3	25	24.3	mg/L
8/7/2018	NO3	25	32.5	mg/L
9/12/2018	NO3	25	23.4	mg/L
10/10/2018	NO3	25	23.6	mg/L
12/5/2018	NO3	25	22.6	mg/L
1/8/2019	NO3	25	22.1	mg/L
11/6/2018	NO3	25	23.9	mg/L
2/20/2019	NO3	25	21.9	mg/L
3/5/2019	NO3	25	23.1	mg/L
4/9/2019	NO3	25	21.4	mg/L
5/8/2019	NO3	25	20.7	mg/L
6/11/2019	NO3	25	21.9	mg/L
7/18/2019	NO3	25	22.7	mg/L
7/18/2019	NO3N	5.65	5.13	mg/L
8/14/2019	NO3	25	22.2	mg/L
8/14/2019	NO3N	5.65	5	mg/L
9/20/2019	NO3	25	22.5	mg/L
9/20/2019	NO3N	5.65	5.07	mg/L
10/8/2019	NO3N	5.65	5.58	mg/L
10/8/2019	NO3	25	24.7	mg/L
11/15/2019	NO3N	5.65	3.72	mg/L
11/15/2019	NO3	25	16.5	mg/L
12/10/2019	NO3N	5.65	5.3	mg/L
12/10/2019	NO3	25	23.5	mg/L
1/7/2020	NO3N	5.65	5.97	mg/L
1/7/2020	NO3	25	26.4	mg/L
2/11/2020	NO3N	5.65	5.71	mg/L
2/11/2020	NO3	25	25.3	mg/L
3/16/2020	NO3N	5.65	5.39	mg/L
3/16/2020	NO3	25	23.9	mg/L
4/21/2020	NO3N	5.65	5.15	mg/L
4/21/2020	NO3	25	22.8	mg/L
5/18/2020	NO3N	5.65	5.32	mg/L
5/18/2020	NO3	25	23.5	mg/L
6/23/2020	NO3N	5.65	5.81	mg/L
6/23/2020	NO3	25	25.7	mg/L
7/2/2020	NO3N	5.65	5.4	mg/L
7/2/2020	NO3	25	24	mg/L

7/2/2020 NO3N	5.65	4.9 mg/L
7/2/2020 NO3	25	22 mg/L
7/20/2020 NO3N	5.65	5.2 mg/L
7/20/2020 NO3	25	23 mg/L
8/18/2020 NO3N	5.65	5.65 mg/L
8/18/2020 NO3	25	25 mg/L
9/24/2020 NO3N	5.65	5.17 mg/L
9/24/2020 NO3	25	22.9 mg/L
10/21/2020 NO3N	5.65	5.29 mg/L
10/21/2020 NO3	25	23.4 mg/L
11/16/2020 NO3N	5.65	5.68 mg/L
11/16/2020 NO3	25	25.1 mg/L
12/14/2020 NO3N	5.65	6.02 mg/L
12/14/2020 NO3	25	26.6 mg/L
1/21/2021 NO3N	5.65	5.71 mg/L
1/21/2021 NO3	25	25.3 mg/L
2/15/2021 NO3N	5.65	5.32 mg/L
2/15/2021 NO3	25	23.6 mg/L
3/22/2021 NO3N	5.65	5.34 mg/L
3/22/2021 NO3	25	23.6 mg/L
4/23/2021 NO3N	5.65	5.14 mg/L
4/23/2021 NO3	25	22.8 mg/L
5/28/2021 NO3N	5.65	5.29 mg/L
5/28/2021 NO3	25	23.4 mg/L
6/15/2021 NO3N	5.65	7.24 mg/L
6/15/2021 NO3	25	32.1 mg/L
6/30/2021 NO3N	5.65	5.07 mg/L
6/30/2021 NO3	25	22.5 mg/L
6/30/2021 NO3N	5.65	4.92 mg/L
6/30/2021 NO3	25	21.8 mg/L
7/13/2021 NO3N	5.65	5.07 mg/L
7/13/2021 NO3	25	22.5 mg/L
9/10/2021 NO3N	5.65	5.12 mg/L
9/10/2021 NO3	25	22.7 mg/L
1/17/2022 NO3N	5.65	5.08 mg/L
1/17/2022 NO3	25	22.5 mg/L
9/10/2021 NO3N	5.65	5.13 mg/L
9/10/2021 NO3	25	22.7 mg/L
10/7/2021 NO3N	5.65	5.13 mg/L
10/7/2021 NO3	25	22.7 mg/L
12/23/2021 NO3N	5.65	5.18 mg/L
12/23/2021 NO3	25	23 mg/L
12/28/2021 NO3N	5.65	5.01 mg/L
12/28/2021 NO3	25	22.2 mg/L
1/17/2022 NO3N	5.65	5.37 mg/L
1/17/2022 NO3	25	23.8 mg/L
2/15/2022 NO3N	5.65	5.18 mg/L
2/15/2022 NO3	25	22.9 mg/L
3/16/2022 NO3N	5.65	5.3 mg/L
3/16/2022 NO3	25	23.5 mg/L

4/14/2022 NO3N	5.65	3.63 mg/L
4/14/2022 NO3	25	16.1 mg/L
5/12/2022 NO3N	5.65	7.49 mg/L
5/12/2022 NO3	25	33.2 mg/L
6/10/2022 NO3N	5.65	5.42 mg/L
6/10/2022 NO3	25	24 mg/L
7/7/2022 NO3N	5.65	5.54 mg/L
7/7/2022 NO3	25	24.5 mg/L
8/12/2022 NO3N	5.65	5.62 mg/L
8/12/2022 NO3	25	24.7 mg/L
9/12/2022 NO3N	5.65	5.19 mg/L
9/12/2022 NO3	25	23 mg/L
10/14/2022 NO3N	5.65	6.5 mg/L
10/14/2022 NO3	25	28.8 mg/L