

Sampling Date	Determinand	1/2 MAV	Result	Units
9/6/2017	NO3	25	31.5	mg/L
11/15/2017	NO3	25	26.8	mg/L
12/4/2017	NO3	25	19.7	mg/L
1/9/2018	NO3	25	28	mg/L
2/5/2018	NO3	25	31	mg/L
3/6/2018	NO3	25	18.4	mg/L
4/3/2018	NO3	25	19.8	mg/L
5/3/2018	NO3	25	19.9	mg/L
6/12/2018	NO3	25	19.1	mg/L
7/10/2018	NO3	25	18.6	mg/L
8/3/2018	NO3	25	20.1	mg/L
9/11/2018	NO3	25	19.6	mg/L
10/3/2018	NO3	25	19.9	mg/L
12/6/2018	NO3	25	19.2	mg/L
11/5/2018	NO3	25	20	mg/L
1/7/2019	NO3	25	19.6	mg/L
2/18/2019	NO3	25	19.7	mg/L
3/12/2019	NO3	25	19	mg/L
4/8/2019	NO3	25	18.1	mg/L
5/7/2019	NO3	25	18.8	mg/L
6/10/2019	NO3	25	19.9	mg/L
7/5/2019	NO3	25	19.9	mg/L
8/13/2019	NO3	25	19.4	mg/L
10/7/2019	NO3N	5.65	4.7	mg/L
10/7/2019	NO3	25	20.8	mg/L
9/25/2019	NO3N	5.65	6.9	mg/L
9/25/2019	NO3	25	30.6	mg/L
11/14/2019	NO3N	5.65	4.79	mg/L
11/14/2019	NO3	25	21.2	mg/L
12/9/2019	NO3N	5.65	4.87	mg/L
12/9/2019	NO3	25	21.6	mg/L
1/6/2020	NO3N	5.65	4.58	mg/L
1/6/2020	NO3	25	20.3	mg/L
2/10/2020	NO3N	5.65	4.51	mg/L
2/10/2020	NO3	25	20	mg/L
3/17/2020	NO3N	5.65	4.43	mg/L
3/17/2020	NO3	25	19.6	mg/L
4/22/2020	NO3N	5.65	7.36	mg/L
4/22/2020	NO3	25	32.6	mg/L
5/20/2020	NO3N	5.65	4.6	mg/L
5/20/2020	NO3	25	21	mg/L
6/22/2020	NO3N	5.65	4.66	mg/L
6/22/2020	NO3	25	20.6	mg/L
7/21/2020	NO3N	5.65	4.4	mg/L
7/21/2020	NO3	25	19.7	mg/L
8/17/2020	NO3N	5.65	4.7	mg/L
8/17/2020	NO3	25	20.8	mg/L
9/21/2020	NO3N	5.65	4.53	mg/L
9/21/2020	NO3	25	20.1	mg/L

10/20/2020 NO3N	5.65	4.31 mg/L
10/20/2020 NO3	25	19.1 mg/L
11/16/2020 NO3N	5.65	4.45 mg/L
11/16/2020 NO3	25	19.7 mg/L
12/14/2020 NO3N	5.65	4.71 mg/L
12/14/2020 NO3	25	20.9 mg/L
1/21/2021 NO3N	5.65	4.58 mg/L
1/21/2021 NO3	25	20.3 mg/L
2/15/2021 NO3N	5.65	4.58 mg/L
2/15/2021 NO3	25	20.3 mg/L
3/23/2021 NO3N	5.65	4.5 mg/L
3/23/2021 NO3	25	19.9 mg/L
4/23/2021 NO3N	5.65	4.51 mg/L
4/23/2021 NO3	25	20 mg/L
5/28/2021 NO3N	5.65	4.63 mg/L
5/28/2021 NO3	25	20.5 mg/L
6/15/2021 NO3N	5.65	4.6 mg/L
6/15/2021 NO3	25	20.4 mg/L
7/13/2021 NO3N	5.65	4.67 mg/L
7/13/2021 NO3	25	20.7 mg/L
9/10/2021 NO3N	5.65	4.86 mg/L
9/10/2021 NO3	25	21.5 mg/L
8/13/2021 NO3N	5.65	4.65 mg/L
8/13/2021 NO3	25	20.6 mg/L
9/10/2021 NO3N	5.65	4.86 mg/L
9/10/2021 NO3	25	21.5 mg/L
10/7/2021 NO3N	5.65	4.74 mg/L
10/7/2021 NO3	25	21 mg/L
12/23/2021 NO3N	5.65	4.6 mg/L
12/23/2021 NO3	25	29.4 mg/L
12/28/2021 NO3N	5.65	4.51 mg/L
12/28/2021 NO3	25	20 mg/L
1/17/2022 NO3N	5.65	4.69 mg/L
1/17/2022 NO3	25	20.8 mg/L
2/15/2022 NO3N	5.65	4.69 mg/L
2/15/2022 NO3	25	20.8 mg/L
3/16/2022 NO3N	5.65	4.68 mg/L
3/16/2022 NO3	25	20.7 mg/L
4/14/2022 NO3N	5.65	4.63 mg/L
4/14/2022 NO3	25	20.5 mg/L
5/12/2022 NO3N	5.65	4.9 mg/L
5/12/2022 NO3	25	21.7 mg/L
6/10/2022 NO3N	5.65	4.67 mg/L
6/10/2022 NO3	25	20.7 mg/L
7/7/2022 NO3N	5.65	4.71 mg/L
7/7/2022 NO3	25	20.9 mg/L
8/12/2022 NO3N	5.65	5.03 mg/L
8/12/2022 NO3	25	22.3 mg/L