

Sampling Date	Determinand	1/2 MAV	Result	Units	Site Description
15/11/2017	NO3	25	9.02	mg/L	Masefield Dr
15/11/2017	NO3	25	11.9	mg/L	Jones Rd
3/05/2018	NO3	25	17.3	mg/L	Masefield Dr
3/05/2018	NO3	25	11.8	mg/L	Jones Rd
5/11/2018	NO3	25	16.7	mg/L	Masefield Dr
5/11/2018	NO3	25	12.7	mg/L	Jones Rd
7/05/2019	NO3	25	15.5	mg/L	Branwaithe Dr
7/05/2019	NO3	25	12.9	mg/L	Jones Rd
14/11/2019	NO3N	5.65	4.79	mg/L	Goldrush Ln
14/11/2019	NO3	25	21.2	mg/L	Goldrush Ln
14/11/2019	NO3N	5.65	2.92	mg/L	Jones Rd
14/11/2019	NO3	25	12.9	mg/L	Jones Rd
20/05/2020	NO3N	5.65	4.6	mg/L	Masefield Dr
20/05/2020	NO3	25	20	mg/L	Masefield Dr
20/05/2020	NO3N	5.65	2.9	mg/L	Jones Rd
20/05/2020	NO3	25	13	mg/L	Jones Rd
16/11/2020	NO3N	5.65	4.37	mg/L	Goldrush Ln
16/11/2020	NO3	25	19.4	mg/L	Goldrush Ln
16/11/2020	NO3N	5.65	2.96	mg/L	Jones Rd
16/11/2020	NO3	25	13.1	mg/L	Jones Rd
28/05/2021	NO3N	5.65	0.054	mg/L	Goldrush Ln
28/05/2021	NO3	25	0.24	mg/L	Goldrush Ln
28/05/2021	NO3N	5.65	2.91	mg/L	Armack Dr
28/05/2021	NO3	25	12.9	mg/L	Armack Dr
3/06/2021	NO3N	5.65	2.98	mg/L	Post Res
3/06/2021	NO3	25	13.2	mg/L	Post Res
3/06/2021	NO3N	5.65	4.6	mg/L	Goldrush Ln
3/06/2021	NO3	25	20.4	mg/L	Goldrush Ln
3/06/2021	NO3N	5.65	3.16	mg/L	Branthwaite Dr
3/06/2021	NO3	25	14	mg/L	Branthwaite Dr
3/06/2021	NO3N	5.65	2.99	mg/L	Jones Rd
3/06/2021	NO3	25	13.2	mg/L	Jones Rd
3/06/2021	NO3N	5.65	2.75	mg/L	East Maddisons Rd

3/06/2021	NO3	25	12.2	mg/L	East Maddisons Rd
3/06/2021	NO3N	5.65	2.96	mg/L	Brunham Road
3/06/2021	NO3	25	13.1	mg/L	Brunham Road
3/06/2021	NO3N	5.65	2.69	mg/L	Burnham School Rd
3/06/2021	NO3	25	11.9	mg/L	Burnham School Rd
3/06/2021	NO3N	5.65	2.96	mg/L	Armack Dr
3/06/2021	NO3	25	13.1	mg/L	Armack Dr
3/06/2021	NO3N	5.65	2.82	mg/L	Dunns Crossing Rd
3/06/2021	NO3	25	12.5	mg/L	Dunns Crossing Rd
3/06/2021	NO3N	5.65	2.74	mg/L	Moreton Green
3/06/2021	NO3	25	12.1	mg/L	Moreton Green
13/07/2021	NO3N	5.65	4.63	mg/L	Goldrush Ln
13/07/2021	NO3	25	20.5	mg/L	Goldrush Ln
13/07/2021	NO3N	5.65	2.84	mg/L	Armack Dr
13/07/2021	NO3	25	12.6	mg/L	Armack Dr
10/09/2021	NO3N	5.65	4.79	mg/L	Goldrush Ln
10/09/2021	NO3	25	21.2	mg/L	Goldrush Ln
10/09/2021	NO3N	5.65	3.46	mg/L	Armack Dr
10/09/2021	NO3	25	15.3	mg/L	Armack Dr
13/08/2021	NO3N	5.65	4.64	mg/L	Goldrush Ln
13/08/2021	NO3	25	20.5	mg/L	Goldrush Ln
13/08/2021	NO3N	5.65	2.85	mg/L	Armack Dr
13/08/2021	NO3	25	12.6	mg/L	Armack Dr
7/10/2021	NO3N	5.65	4.74	mg/L	Goldrush Ln
7/10/2021	NO3	25	21	mg/L	Goldrush Ln
7/10/2021	NO3N	5.65	3.13	mg/L	Armack Dr
7/10/2021	NO3	25	13.9	mg/L	Armack Dr
12/10/2021	NO3N	5.65	2.94	mg/L	Helpet Post Res
12/10/2021	NO3	25	13	mg/L	Helpet Post Res
12/10/2021	NO3N	5.65	2.02	mg/L	Post Res
12/10/2021	NO3	25	8.9	mg/L	Post Res
12/10/2021	NO3N	5.65	3	mg/L	Post Res
12/10/2021	NO3	25	13.3	mg/L	Post Res
23/12/2021	NO3N	5.65	3.32	mg/L	Burnham School Rd

23/12/2021	NO3	25	14.7	mg/L	Burnham School Rd
23/12/2021	NO3N	5.65	2.98	mg/L	Burnham Rd
23/12/2021	NO3	25	13.2	mg/L	Burnham Rd
28/12/2021	NO3N	5.65	2.87	mg/L	Jones Rd
28/12/2021	NO3	25	12.7	mg/L	Jones Rd
28/12/2021	NO3N	5.65	2.89	mg/L	Armack Dr
28/12/2021	NO3	25	12.8	mg/L	Armack Dr
17/01/2022	NO3N	5.65	4.66	mg/L	Goldrush Ln
17/01/2022	NO3	25	20.6	mg/L	Goldrush Ln
20/01/2022	NO3N	5.65	3.34	mg/L	Burnham School Rd
20/01/2022	NO3	25	14.8	mg/L	Burnham School Rd
15/02/2022	NO3N	5.65	3.02	mg/L	Jones Rd
15/02/2022	NO3	25	13.4	mg/L	Jones Rd
15/02/2022	NO3N	5.65	2.98	mg/L	Branthwaite Dr
15/02/2022	NO3	25	13.2	mg/L	Branthwaite Dr
16/03/2022	NO3N	5.65	2.94	mg/L	Burnham School Rd
16/03/2022	NO3	25	13	mg/L	Burnham School Rd
16/03/2022	NO3N	5.65	2.92	mg/L	East Maddisons Rd
16/03/2022	NO3	25	12.9	mg/L	East Maddisons Rd
14/04/2022	NO3N	5.65	2.92	mg/L	Jones Rd
14/04/2022	NO3	25	12.9	mg/L	Jones Rd
14/04/2022	NO3N	5.65	2.05	mg/L	Burnham Rd
14/04/2022	NO3	25	9.1	mg/L	Burnham Rd
12/05/2022	NO3N	5.65	3.2	mg/L	Burnham School Rd
12/05/2022	NO3	25	14.2	mg/L	Burnham School Rd
12/05/2022	NO3N	5.65	4.77	mg/L	Dunns Crossing Rd
12/05/2022	NO3	25	21.1	mg/L	Dunns Crossing Rd
10/06/2022	NO3N	5.65	2.28	mg/L	Jones Rd
10/06/2022	NO3	25	13.2	mg/L	Jones Rd
10/06/2022	NO3N	5.65	2.79	mg/L	Moreton Green
10/06/2022	NO3	25	12.4	mg/L	Moreton Green
7/07/2022	NO3N	5.65	3.03	mg/L	Burnham School Rd
7/07/2022	NO3	25	13.4	mg/L	Burnham School Rd
7/07/2022	NO3N	5.65	3.02	mg/L	Armack Dr

7/07/2022	NO3	25	13.4	mg/L	Armack Dr
12/08/2022	NO3N	5.65	3.12	mg/L	Jones Rd
12/08/2022	NO3	25	13.7	mg/L	Jones Rd
12/08/2022	NO3N	5.65	5.07	mg/L	Goldrush Ln
12/08/2022	NO3	25	22.5	mg/L	Goldrush Ln
12/09/2022	NO3N	5.65	2.9	mg/L	Burnham School Rd
12/09/2022	NO3	25	12.8	mg/L	Burnham School Rd
12/09/2022	NO3N	5.65	4.34	mg/L	Branthwaite Dr
12/09/2022	NO3	25	19.2	mg/L	Branthwaite Dr
14/10/2022	NO3N	5.65	2.71	mg/L	Burnham School Rd
14/10/2022	NO3	25	12	mg/L	Burnham School Rd
14/10/2022	NO3N	5.65	2.46	mg/L	East Maddisons Rd
14/10/2022	NO3	25	10.8	mg/L	East Maddisons Rd
10/11/2022	NO3N	5.65	2.94	mg/L	Jones Rd
10/11/2022	NO3	25	13	mg/L	Jones Rd
10/11/2022	NO3N	5.65	2.41	mg/L	Burnham Rd
10/11/2022	NO3	25	10.7	mg/L	Burnham Rd
8/12/2022	NO3N	5.65	2.63	mg/L	Dunns Crossing Rd
8/12/2022	NO3	25	11.7	mg/L	Dunns Crossing Rd
8/12/2022	NO3N	5.65	2.43	mg/L	Burnham School Rd
8/12/2022	NO3	25	10.8	mg/L	Burnham School Rd
12/01/2023	NO3N	5.65	2.94	mg/L	Jones Rd
12/01/2023	NO3	25	13	mg/L	Jones Rd
12/01/2023	NO3N	5.65	2.06	mg/L	Moreton Green
12/01/2023	NO3	25	9.1	mg/L	Moreton Green
28/02/2023	NO3N	5.65	2.68	mg/L	Burnham School Rd
28/02/2023	NO3	25	11.9	mg/L	Burnham School Rd
28/02/2023	NO3N	5.65	2.98	mg/L	Armack Dr
28/02/2023	NO3	25	13.2	mg/L	Armack Dr
8/03/2023	NO3N	5.65	2.74	mg/L	Jones Rd
8/03/2023	NO3	25	12.1	mg/L	Jones Rd
8/03/2023	NO3N	5.65	4.36	mg/L	Goldrush Ln
8/03/2023	NO3	25	19.3	mg/L	Goldrush Ln
25/03/2023	NO3N	5.65	2.29	mg/L	Burnham School Rd

25/03/2023	NO3	25	10.2	mg/L	Burnham School Rd
10/04/2023	NO3N	5.65	2.32	mg/L	Raven Dr
10/04/2023	NO3	25	10.3	mg/L	Raven Dr
10/04/2023	NO3N	5.65	4.13	mg/L	Branthwaite Dr
10/04/2023	NO3	25	18.3	mg/L	Branthwaite Dr
10/04/2023	NO3N	5.65	2.55	mg/L	Burnham School Rd
10/04/2023	NO3	25	11.3	mg/L	Burnham School Rd
4/05/2023	NO3N	5.65	3.07	mg/L	Raven Dr
4/05/2023	NO3	25	13.6	mg/L	Raven Dr
4/05/2023	NO3N	5.65	3.72	mg/L	Branthwaite Dr
4/05/2023	NO3	25	16.5	mg/L	Branthwaite Dr
4/05/2023	NO3N	5.65	3.13	mg/L	Burnham School Rd
4/05/2023	NO3	25	13.9	mg/L	Burnham School Rd
8/06/2023	NO3N	5.65	2.97	mg/L	Jones Rd
8/06/2023	NO3	25	13.1	mg/L	Jones Rd
8/06/2023	NO3N	5.65	2.97	mg/L	Armack Dr
8/06/2023	NO3	25	13.2	mg/L	Armack Dr
8/06/2023	NO3N	5.65	2.33	mg/L	East Maddisons Rd
8/06/2023	NO3	25	10.3	mg/L	East Maddisons Rd
5/07/2023	NO3N	5.65	2.2	mg/L	Burnham School Rd
5/07/2023	NO3	25	9.8	mg/L	Burnham School Rd
5/07/2023	NO3N	5.65	4.69	mg/L	Goldrush Ln
5/07/2023	NO3	25	20.8	mg/L	Goldrush Ln
15/08/2023	NO3N	5.65	3.65	mg/L	Jones Rd
15/08/2023	NO3	25	16.2	mg/L	Jones Rd
15/08/2023	NO3N	5.65	2.87	mg/L	Branthwaite Dr
15/08/2023	NO3	25	12.7	mg/L	Branthwaite Dr
14/09/2023	NO3N	5.65	2.57	mg/L	Burnham School Rd
14/09/2023	NO3	25	11.4	mg/L	Burnham School Rd
14/09/2023	NO3N	5.65	2.66	mg/L	East Maddisons Rd
14/09/2023	NO3	25	11.8	mg/L	East Maddisons Rd
2/10/2023	NO3N	5.65	2.87	mg/L	Jones Rd
2/10/2023	NO3	25	12.7	mg/L	Jones Rd
2/10/2023	NO3N	5.65	2.35	mg/L	Burnham School Rd

2/10/2023	NO3	25	10.4	mg/L	Burnham School Rd
9/11/2023	NO3N	5.65	2.66	mg/L	Raven Drive
9/11/2023	NO3	25	11.8	mg/L	Raven Drive
9/11/2023	NO3N	5.65	2.53	mg/L	Burnham School Rd
9/11/2023	NO3	25	11.2	mg/L	Burnham School Rd
7/12/2023	NO3N	5.65	2.69	mg/L	Raven Drive
7/12/2023	NO3	25	11.9	mg/L	Raven Drive
7/12/2023	NO3N	5.65	2.86	mg/L	Burnham School Rd
7/12/2023	NO3	25	12.7	mg/L	Burnham School Rd
11/01/2024	NO3N	5.65	2.97	mg/L	Jones Rd
11/01/2024	NO3	25	13.1	mg/L	Jones Rd
11/01/2024	NO3N	5.65	2.14	mg/L	Moreton Green
11/01/2024	NO3	25	9.5	mg/L	Moreton Green
12/02/2024	NO3N	5.65	2.92	mg/L	Burnham School Rd
12/02/2024	NO3	25	12.9	mg/L	Burnham School Rd
12/02/2024	NO3N	5.65	2.82	mg/L	Armack Dr
12/02/2024	NO3	25	12.5	mg/L	Armack Dr
15/03/2024	NO3N	5.65	2.73	mg/L	Jones Rd
15/03/2024	NO3	25	12.1	mg/L	Jones Rd
15/03/2024	NO3N	5.65	4.15	mg/L	Goldrush Ln
15/03/2024	NO3	25	18.4	mg/L	Goldrush Ln
16/04/2024	NO3N	5.65	2.26	mg/L	Burnham School Rd
16/04/2024	NO3	25	10	mg/L	Burnham School Rd
16/04/2024	NO3N	5.65	3.3	mg/L	Branthwaite Dr
16/04/2024	NO3	25	14.6	mg/L	Branthwaite Dr