



PHOTO OF SITE TAKEN FROM SOUTHERN  
END OF CHIP SEALED BAY

HYDRANT FORMING BULK  
WATER EXTRACTION POINT  
ON NORTH SIDE OF CAGE

CHIP SEALED BULK WATER  
EXTRACTION FILLING POINT BAY

HYDRANT FORMING BULK WATER EXTRACTION POINT.  
NOTE: CONTRACTOR MUST USE BACKFLOW  
PREVENTED UPSTAND DURING FILLING.

ABOVE GROUND BACKFLOW RPZ  
PREVENTOR IN ABOVE GROUND CAGE

KIOSK, WATER QUALITY  
MONITORING AND SCADA  
SITE

POWER



LOCALITY MAP

BULK WATER  
EXTRACTION  
SITE LOCATION

**SURVEY ACCURACY**  
GPS: Hz +/-20mm, Vt+/-30mm  
Total Station: +/-5mm, Vt+/-10mm

**COPYRIGHT**  
This drawing, the design and concept, remain the exclusive property of CORDE and may not be used without approval. Copyright reserved.

SCALE=1:200

Survey Information:		Detail:	
Surveyor:	GB		
Date of Survey:	23/05/2023		
Equipment Used:	Trimble GPS		
Origin Name/Code:	EMGL		
Coordinate System:	New Zealand/NZGD2000   NZ Transverse Mercator (NZTM)		
Coordinates:	5184341.391m N   1527205.428m E		
Height Datum:	NZVD 2016		
Height:	199.34		

Selwyn  
DISTRICT COUNCIL

CORDE Ltd 85 Hoskyns Rd, Rolleston, Christchurch 7643 www.corde.nz		
Drawn	Designed	
GB	**	Approved
JF		Revision Date
23/05/2023		
Project No.	Scale	
B02.T3786	(A3) 1:200	

Project MATHAIS STREET BULK WATER FILLING POINT	
Title As Built Water Services	
Drawing No.	Sheet No.
B02.T3786.1	1/1
Revision	A